

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-1645:124

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADEMCO, DBA Honeywell International Inc.,
2 Corporate Center Drive, Ste 100, Melville, New York 11747
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

DESIGN: Model 5110XM fire alarm control unit. Power-limited, automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations.
Minimum system components:

5110XM	Control Unit
BE28163001	Basler Electric Transformer
6137, 6137-R, 6139, 6139-R	Keypad

RATING: Primary 120 VAC, 18 VAC Secondary, 12 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: Formerly 7165-0078:175

01-14-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

